




FTB-80-203




FTB-80-663




FTB-80-324




FTB-100-203




FTB-100-663




FTB-100-324




FTB-150-203
























FTB-150-663



FTB-150-324





FTB-80-203-H**FTB-80-663-H****FTB-80-324-H****FTB-100-203-H****FTB-100-663-H****FTB-100-324-H****FTB-150-203-H****FTB-150-663-H****FTB-150-324-H**

FTB-80-203-L**FTB-80-663-L****FTB-80-324-L****FTB-80-355-L****FTB-100-203-L****FTB-100-663-L****FTB-100-324-L****FTB-100-355-L****FTB-150-203-L****FTB-150-663-L****FTB-150-324-L****FTB-150-355-L**


1 Method of connecting EMI/EMC Filter

(1) Single Phase




※Three phase EMI/EMC filter is also available as a single phase input type.

(2) Three phase (Delta-connection)



(3) Three phase (Star-connection)



[Reference] Example of calculating input current calculation

Input voltage 400 [V]


Input capacity of the equipment 4000 [VA]

$$\text{Input current} = \frac{4000 \text{ [VA]}}{400 \text{ [V]} \times \sqrt{3}} = 5.8 \text{ [A]}$$

2 Connection with a general-purpose inverter (servo driver)

The EMI/EMC Filter cannot be used between the inverter (servo driver) and the motor, because the EMI/EMC Filter might cause abnormal heat.


Please connect the EMI/EMC Filter to input side of inverter driver (servo driver).



3 Safety Considerations

- To apply for safety standard approval using this EMI/EMC Filter, the following conditions must be met.
 - The unit must be used as a component of an end-use equipment.
 - Protection earth terminal (PE) must be connected to safety ground of end-use equipment.

1 Noise Transmission



Noise transmission between electric power
and electronic device

- ① Conducted noise from electric power lines.
- ② Radiated noise which is picked up and generated by the power line as antenna.
- ③ Conducted and radiated noise which is generated in the electronic device.
- ④ Conducted noise which is generated by the signal lines between electronic devices.
- ⑤ Radiated noise emitted by an electronic device that interferes with other device.
- ⑥ Radiated noise which is picked up and generated by the signal line as antenna.

2 Application Precautions


The following points should be kept in mind to use the EMI/EMC Filter more effectively.

- Input wire and output wire of the EMI/EMC Filter should be separated.

When the input/output wire are bundled together or wired parallel with each other, high frequency noise is induced so, and the expected effect of noise attenuation cannot be achieved.



Good wiring example



Bad wiring example

- Ground lines should be as short as possible. If it is not, an equivalent inductance appears, and the high frequency attenuation characteristics degrade. When grounding the mounting plate of the EMI/EMC Filter, you should remove the paint to reduce the contact resistance from the equipment case, and then install the EMI/EMC Filter.

3 Method of measuring characteristic data

※ Attenuation = $20\log(U_0/U_\infty)$ [dB]
 U_0 : Voltage in state without filters
 U_∞ : Voltage in state which added filters
※ N.A. : Network analyzer

(1) Attenuation Characteristic(Static characteristic)

Object product:Single phase input type




Fig.3.1 Differential mode attenuation measurement diagram




Fig.3.2 Common mode attenuation measurement diagram

Object product:Three phase input type




Fig.3.3 Differential mode attenuation measurement diagram




Fig.3.4 Common mode attenuation measurement diagram

Object product:DC input type




Fig.3.5 Differential mode attenuation measurement diagram




Fig.3.6 Common mode attenuation measurement diagram

(2) Pulse Attenuation Characteristic




Fig.3.7 Pulse attenuation measurement diagram