



Ref. Certif. No.

JP-26099-UL

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Switching Power Supply
Name and address of the applicant	COSEL CO LTD 1-6-43 KAMIAKAE-MACHI TOYAMA-SHI TOYAMA 930-0816 JAPAN
Name and address of the manufacturer	COSEL CO LTD 1-6-43 KAMIAKAE-MACHI TOYAMA-SHI TOYAMA 930-0816 JAPAN
Name and address of the factory	COSEL CO LTD TATEYAMA FACTORY 78 DOGENJI TATEYAMAMACHI NAKANIIKAWA-GUN TOYAMA 930-0241 JAPAN <input checked="" type="checkbox"/> Additional Information on page 2
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	See Page 2
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	KHxA60F-12, KHxA60F-24 "x" = "E" or "N". May be followed by "-C".
Additional information (if necessary may also be reported on page 2)	Additionally evaluated to EN IEC 62368-1:2020/ A11:2020. National Differences specified in the CB Test Report. <input type="checkbox"/> Additional Information on page 2
A sample of the product was tested and found to be in conformity with	IEC 62368-1:2018
As shown in the Test Report Ref. No. which forms part of this Certificate	E132067-A6104-CB-1 issued on 2022-04-24

This CB Test Certificate is issued by the National Certification Body



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-04-25

Signature:

Masamichi Takagi



Ref. Certif. No.

JP-26099-UL

Factory(ies):

WUXI COSEL ELECTRONICS CO LTD
5TH FL, BLD A3, NO.866 LIYUAN DEVELOPMENT ZONE WUXI JIANGSU 214072
CHINA

Ratings:

Input Ratings:

100-240 VAC, 50-60 Hz, 1.1 A (Model KHxA60F-12), 1.2 A (Model KHxA60F-24)

88-250 VDC, 0.75 A (Model KHxA60F-12), 0.82 A (Model KHxA60F-24)

Output Ratings: See Test Report

Additional information (if necessary)



- UL (US), 333 Pfingsten Rd IL 60062, Northbrook, USA
- UL (Demko), Borupvang 5A DK-2750 Ballerup, DENMARK
- UL (JP), Marunouchi Trust Tower Main Building 6F, 1-8-3 Marunouchi, Chiyoda-ku, Tokyo 100-0005, JAPAN
- UL (CA), 7 Underwriters Road, Toronto, M1R 3B4 Ontario, CANADA

For full legal entity names see www.ul.com/ncbnames

Date: 2022-04-25

Signature:

M. Takagi
Masamichi Takagi