



**KRE-20A EMI/EMS Test result**

November 30, 2015  
Design engineering dep.

Approved : Yukihiro Takehashi  
Yukihiro Takehashi

Prepared : Yasunari Hirano  
Yasunari Hirano

No.	Test item	Conditions	Conditions of Acceptability	Result
1	Line conduction	(1) Rated input DC24V (2) Rated load (3) Ambient temp. 25±10°C	(1)Meets the undermentioned standard. FCC Part15 classB , VCCI classB CISPR22 classB , EN55022-B EN55011-B	OK
2	Radiated emission	(1) Rated input DC24V (2) Rated load (3) Ambient temp. 25±10°C	(1)Meets the undermentioned standard. FCC Part15 classB , VCCI classB CISPR22 classB , EN55022-B EN55011-B	OK
3	Static electricity immunity test (EN61000-4-2)	(1) Rated input DC24V (2) Rated load (3) Ambient temp. 25±10°C (4) Contact discharge voltage 8[kV] (Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK
4	Radiated, radio-frequency, electromagnetic field immunity test (EN61000-4-3)	(1) Rated input DC24V (2) Rated load (3) Ambient temp. 25±10°C (4)Testing field strength (Level 3) ① 10[V/m] (80MHz to 1.0GHz) ② 3[V/m] (1.4GHz to 2.0GHz) ③ 1[V/m] (2.0GHz to 2.7GHz)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK
5	Electrical fast transient/ burst immunity test (EN61000-4-4)	(1) Rated input DC24V (2) Rated load (3) Ambient temp. 25±10°C (4) Test peak voltage 4[kV] (Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK
6	Immunity to conducted disturbances, induced by radio-frequency fields. (EN61000-4-6)	(1) Rated input DC24V (2) Rated load (3) Ambient temp. 25±10°C (4) Voltage level (e.m.f.) 10[V] (Level 3)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK