



Certificate of Compliance

Certificate: 70102323

Master Contract: 174688

Project: 80038865

Date Issued: April 16, 2020

Issued to: Cosel Co., Ltd.
 1-6-43 Kamiakae-machi
 Toyama-shi, Toyama 930-0816
 JAPAN
 Attention: Mr. Shinichi Yokoyama

The products listed below are eligible to bear the CSA Mark shown



Issued by:

Masato Endo

PRODUCTS

CLASS - C531111 - POWER SUPPLIES-Component Type(CSA 60950-1-07-2nd Ed)

<u>Model</u>	<u>Level</u>	<u>V</u>	<u>A</u>	<u>Hz</u>	<u>V</u>	<u>A</u>
LDA30F-3	3	100-240 (ac)	0.5	50-60	3	6.0
		110-370 (dc)	0.25	dc	"	"
LDA30F-5	3	100-240 (ac)	0.8	50-60	5	6.0
		110-370 (dc)	0.4	dc	"	"
LDA30F-12	3	100-240 (ac)	0.8	50-60	12	2.5
		110-370 (dc)	0.4	dc	"	"
LDA30F-15	3	100-240 (ac)	0.8	50-60	15	2.0
		110-370 (dc)	0.4	dc	"	"
LDA30F-24	3	100-240 (ac)	0.8	50-60	24	1.3
		110-370 (dc)	0.4	dc	"	"

Notes:

- May be followed by suffix S or SN or G. Suffix "S" indicates optional chassis provided. Suffix "SN" indicates optional chassis and cover provided. Suffix "G" indicates capacitors C14, C15, rated less than 3300 pF.
- Component type power supplies for use with Information Technology and Electrical Business Equipment where the suitability of the combination is determined by the CSA Group.



Certificate: 70102323

Master Contract: 174688

Project: 80038865

Date Issued: April 16, 2020

- c) Evaluation for Resistance to Abnormal Heat (Ball Pressure) Test, Earth Continuity Test and Limited Short-circuit Test shall be performed in the end equipment (LDA30F Series).
- d) This certification report supersedes the certification report 174688 – 1107927 (LR 60474 – 166).

APPLICABLE REQUIREMENTS

CAN/CSA C22.2 No. 60950-1-07 +
Am1:2011 + Am2:2014

- Information Technology Equipment - Safety - Part 1: General
Requirements