



STMGFS30/STMGF30 Series EMI/EMS Test results

Approved : *Takahiro Yoneda*
Takahiro Yoneda

Prepared : *Satoshi Kinoshita*
Satoshi Kinoshita

No.	Test item	Conditions	Conditions of Acceptability	Result
1	Line conduction	(1) Rated input (2) Rated load (3) Ambient temp. 25±10°C	(1)Meets the undermentioned standard. FCC Part15 classA , VCCI classA CISPR11 classA , EN55011-A	OK
2	Radiated emission	(1) Rated input (2) Rated load (3) Ambient temp. 25±10°C	(1)Meets the under mentioned standard. FCC Part15 classA , VCCI classA CISPR11 classA , EN55011-A	OK
3	Static electricity immunity test (EN61000-4-2)	(1) Rated input (2) Rated load (3) Ambient temp. 25±10°C (4) Contact discharge voltage 8[kV] (EN61000-4-2 Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK
4	Radiated, radio-frequency, electromagnetic field immunity test (EN61000-4-3)	(1) Rated input (2) Rated load (3) Ambient temp. 25±10°C (4)Testing field strength 10[V/m] (EN61000-4-3 Level 3)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK
5	Electrical fast transient/ burst immunity test (EN61000-4-4)	(1) Rated input (2) Rated load (3) Ambient temp. 25±10°C (4) Test peak voltage 4[kV] (IEC61000-4-4 Level 4)	(1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure.	OK
6	Surge immunity test (EN61000-4-5)	(1) Rated input (2) Rated load (3) Ambient temp. 25±10°C (4) Test voltage Line to line 0.5[kV] (Level 1) Line to earth 2[kV] (Level 3)	(1)The power supply is not stop. (2)Circuit does not malfunction. (3)No abnormality of the insulation destruction etc. (4)Parts are no damaged.	OK