

DATA SHEET		Date	Jul.13,1999
Model	DBS400B03	Temp.	25 °C
Test	Vibration/Impact test 振動・衝撃試験	Humid.	45 %Rh
		Tested by	H.Senda

1. Method  
Vibration/impact test complies with JIS C 0911 (Vibration), JIS C 0912 (Impact)  
JIS C 0911 (振動), JIS C 0912 (衝撃) に準ずる

2. Conditions

(1) Vibration : 10~55 Hz  
振動 3 minutes period  
1 hour each X, Y and Z axis

(2) Impact : 11mS  
衝撃 once each X, Y and Z axis

3. Conditions of Acceptability

(1) No degradation of performance or loss of function after test.  
試験後、諸機能が正常であること

(2) No remakably damage of appearance.  
外観上著しい損傷がないこと

(3) No looseness or a crack at solder joint.  
はんだ付け、圧着など電氣的接合部分にクラックや緩みの発生がないこと

4. Result

(1) Vibration limit test

No.	Gravity [m/S <sup>2</sup> ]	Result	Note
1	49.0 (5G)	OK	
2	—	—	

All are satisfactory to item 3: OK

(2) Impact test

No.	Gravity [m/S <sup>2</sup> ]	Result	Note
1	196.1 (20G)	OK	
2	—	—	

All are satisfactory to item 3: OK