

TEST DATA OF EAP-06-□□□/ESP-06-□□□**Noise Filter**

Nov. 30. 2010

Approved by : Toshio Watanabe
Toshio Watanabe

Design Manager

Prepared by : Tadayuki Noda
Tadayuki Noda

Design Engineer

COSEL CO.,LTD.





CONTENTS

1.Attenuation Characteristics	1
2.Pulse Attenuation Characteristics	6
3.Leakage Current	9
4.Figure of Testing Circuitry	10


(Final Page 11)

COSEL


Model	EAP-06-□□□/ESP-06-□□□	Temperature Testing Circuitry Figure A	25°C
Item	Attenuation Characteristics		
Object	—		




COSEL



COSEL



COSEL



COSEL

Model EAP-06-□□□/ESP-06-□□□

Temperature 25°C
Testing Circuitry Figure A





Item Attenuation Characteristics


Object _____



COSEL

Model	EAP-06-□□□/ESP-06-□□□	Temperature Testing Circuitry	25°C Figure B
Item	Pulse Attenuation Characteristics		
Object	_____		



COSEL

COSEL

Model	EAP-06-□□□/ESP-06-□□□	Temperature Testing Circuitry Figure B	25°C
Item	Pulse Attenuation Characteristics		
Object	—		

EAP-06-332/ESP-06-332 Pulse Width: 1 μ s

Output Voltage[V]

Input Voltage[kV]

EAP-06-472/ESP-06-472 Pulse Width: 1 μ s

Output Voltage[V]

Input Voltage[kV]



Model	EAP-06-□□□/ESP-06-□□□	Temperature	25°C
Item	Leakage Current	Testing Circuitry	Figure C
Object	_____		

1. Results

[mA]

Model	Standards	Input Volt.				Note
		100 [V]	125 [V]	230 [V]	250 [V]	
EAP-06-000 ESP-06-000	UL1283	0.002	0.002	0.004	0.005	
EAP-06-101 ESP-06-101	UL1283	0.006	0.007	0.013	0.015	
EAP-06-221 ESP-06-221	UL1283	0.011	0.013	0.025	0.028	
EAP-06-331 ESP-06-331	UL1283	0.015	0.019	0.038	0.042	
EAP-06-471 ESP-06-471	UL1283	0.023	0.030	0.061	0.069	
EAP-06-681 ESP-06-681	UL1283	0.031	0.040	0.082	0.093	
EAP-06-102 ESP-06-102	UL1283	0.044	0.056	0.110	0.120	
EAP-06-222 ESP-06-222	UL1283	0.090	0.120	0.230	0.250	
EAP-06-332 ESP-06-332	UL1283	0.130	0.170	0.340	0.370	
EAP-06-472 ESP-06-472	UL1283	0.190	0.240	0.480	0.520	

2. Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.

COSEL




Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement

COSEL




Figure B Pulse attenuation measurement




Figure C Leakage current measurement (UL1283)