参考資料

COSEL

TEST DATA OF LEA100F-15

(200V INPUT)

Regulated DC Power Supply

Date : Feb.9. 1999

Approved by : T. Watanabe
Design Manager

Prepared by : T. Miura
Design Engineer

コーセル株式会社

COSEL CO.,LTD.

COSEL

CONTENTS

(Final Page 30)

COSEL

Model	LEA100F-15
Item	Line Regulation 静的入力変動
Object	+15V6.7A

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated input voltage.

(注)斜線は定格入力電圧範囲を示す。

2. Values

Input Voltage [V]	Load 50% Output Volt. [V]	Load 100% Output Volt. [V]
150	15.132	15.129
160	15.132	15.129
170	15.132	15.129
180	15.132	15.129
200	15.132	15.129
220	15.132	15.129
240	15.132	15.129
264	15.132	15.129
280	15.132	15.129

BC−3165

COSEL

Model	LEA100F-15
Item	Input Current (by Load Current) 入力電流（負荷特性）
Output	————

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated load current

(注)斜線は定格負荷電流範囲を示す。

2. Values

Load Current [A]	Input Current [A]		
	Input Volt. 170[V]	Input Volt. 200[V]	Input Volt. 264[V]
0.00	0.065	0.068	0.090
1.00	0.184	0.167	0.151
2.00	0.287	0.254	0.216
3.00	0.387	0.340	0.280
4.00	0.487	0.424	0.344
5.00	0.590	0.511	0.409
6.00	0.691	0.596	0.473
6.70	0.760	0.656	0.517
7.37	0.832	0.715	0.563
—	—	—	—
—	—	—	—
—	—	—	—

BC−3165

COSEL

Model	LEA100F-15
Item	Input Power (by Load Current) 入力電力 (負荷特性)
Output	————

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated load current

(注)斜線は定格負荷電流範囲を示す。

2. Values

Load Current [A]	Input Power [W] Input Volt. 170[V]	Input Volt. 200[V]	Input Volt. 264[V]
0.00	5.40	5.50	8.60
1.00	25.20	25.20	25.50
2.00	42.40	42.30	42.40
3.00	59.60	59.40	59.20
4.00	76.80	76.40	76.10
5.00	94.50	93.90	93.40
6.00	111.80	111.20	110.40
6.70	123.90	123.20	122.20
7.37	136.40	135.50	134.40
—	—	—	—
—	—	—	—
—	—	—	—

BC−3165

COSEL

Model	LEA100F-15	
Item	Efficiency (by Input Voltage) 効率（入力電圧特性）	Temperature 25℃ Testing Circuitry Figure A
Object	———————————	

1. Graph



Note: Slanted line shows the range of the rated input voltage.

(注)斜線は定格入力電圧範囲を示す。

2. Values

Input Voltage [V]	Load 50% Efficiency [%]	Load 100% Efficiency [%]
150	77.7	81.7
160	77.9	82.0
170	78.1	82.2
180	78.2	82.4
200	78.3	82.8
220	78.4	83.0
240	78.5	83.3
264	78.5	83.4
280	76.0	83.3

COSEL

Model	LEA100F-15
Item	Efficiency (by Load Current) 効率 (負荷電流特性)
Output	————

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated load current

(注)斜線は定格負荷電流範囲を示す。

2. Values

Load Current [A]	Efficiency [%] Input Volt. 170[V]	Input Volt. 200[V]	Input Volt. 264[V]
1.00	60.4	60.4	59.7
2.00	71.9	72.1	71.9
3.00	76.9	77.1	77.4
4.00	79.4	79.8	80.1
5.00	80.8	81.3	81.7
6.00	81.8	82.3	82.8
6.70	82.2	82.8	83.4
7.37	82.3	83.0	83.5
—	—	—	—
—	—	—	—
—	—	—	—
—	—	—	—

BC−3165

COSEL

Model	LEA100F-15
Item	Power Factor (by Input Voltage) 力率（入力電圧特性）
Object	———————————

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated input voltage.

(注)斜線は定格入力電圧範囲を示す。

2. Values

Input Voltage [V]	load 50% Power Factor	load 100% Power Factor
150	0.94	0.97
160	0.93	0.96
170	0.92	0.96
180	0.91	0.95
200	0.89	0.94
220	0.87	0.93
240	0.85	0.91
264	0.83	0.90
280	0.51	0.66

COSEL

Model	LEA100F-15
Item	Power Factor (by Load Current) 力率 (負荷電流特性)
Output	————

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated load current

(注)斜線は定格負荷電流範囲を示す。

2. Values

Load Current [A]	Power Factor Input Volt. 170[V]	Input Volt. 200[V]	Input Volt. 264[V]
0.00	0.49	0.40	0.36
1.00	0.81	0.75	0.64
2.00	0.87	0.83	0.74
3.00	0.91	0.87	0.80
4.00	0.93	0.90	0.84
5.00	0.94	0.92	0.86
6.00	0.95	0.93	0.88
6.70	0.96	0.94	0.90
7.37	0.96	0.95	0.90
—	—	—	—
—	—	—	—
—	—	—	—

COSEL

Model	LEA100F-15
Item	Hold-Up Time　出力保持時間
Object	+15V6.7A

Temperature　25℃
Testing Circuitry　Figure A

1. Graph



This duration covers from Shut-off of input voltage to the moment when output voltage descends to the rated range of voltage accuracy.

Note: Slanted line shows the range of the rated input voltage.

出力保持時間とは、入力電圧断から出力電圧が、定電圧精度の規格範囲を保持しているところまでの時間。

(注)斜線は定格入力電圧範囲を示す。

2. Values

Input Voltage [V]	Load 50% Hold-Up Time [mS]	Load 100% Hold-Up Time [mS]
150	78	37
160	78	38
170	79	38
180	79	39
200	80	39
220	81	40
240	81	40
264	82	40
280	82	41

COSEL

Model	LEA100F-15
Item	Instantaneous Interruption Compensation 瞬時停電保障
Object	+15V6.7A

Temperature 25℃
Testing Circuitry Figure A

1. Graph



This duration covers from Shut-off of input voltage to the moment when output voltage descends to the rated range of voltage accuracy.
Note:Slanted line shows the range of the rated load current.

瞬時停電保障時間とは、出力電圧が定電圧精度の規格範囲を保持している瞬時停電時間をいう。
(注)斜線は定格負荷電流範囲を示す。

2. Values

Load Current [A]	Input Volt. 170[V]	Input Volt. 200[V]	Input Volt. 264[V]
	Time [mS]		
0.00	—	—	—
1.00	224	230	236
2.00	122	127	131
3.00	80	85	89
4.00	59	63	67
5.00	48	51	54
6.00	41	43	45
6.70	37	39	40
7.37	33	35	36
—	—	—	—
—	—	—	—

COSEL

Model	LEA100F-15
Item	Load Regulation 静的負荷変動
Object	+15V6.7A

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated load current.

(注)斜線は定格負荷電流範囲を示す。

2. Values

Load Current [A]	Input Volt. 170[V] Output Volt. [V]	Input Volt. 200[V] Output Volt. [V]	Input Volt. 264[V] Output Volt. [V]
0.00	15.137	15.137	15.136
1.00	15.135	15.135	15.135
2.00	15.134	15.134	15.134
3.00	15.133	15.133	15.133
4.00	15.133	15.132	15.132
5.00	15.132	15.131	15.131
6.00	15.131	15.131	15.130
6.70	15.130	15.130	15.130
7.37	15.130	15.129	15.129
—	—	—	—

COSEL

Model	LEA100F-15
Item	Ripple Voltage(by Load Current) リップル電圧(負荷電流特性)
Object	+15V6.7A

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Ripple Voltage is shown as p-p in the figure below.

Note: Slanted line shows the range of the rated load current.

リップル電圧は、下図ｐ－ｐ値で示される。

(注)斜線は定格負荷電流範囲を示す。

T1: Due to AC Input Line
入力商用周期
T2: Due to Switching
ｽｲｯﾁﾝｸﾞ周期



Fig. Complex Ripple Wave Form
図 リップル波形詳細図

2. Values

Load Current [A]	Input Volt. 170 [V] Ripple Output Volt. [mV]	Input Volt. 264 [V] Ripple Output Volt. [mV]
0.0	10	10
1.0	30	30
2.0	30	30
3.0	35	35
4.0	35	35
5.0	35	35
6.7	40	40
7.4	45	45
—	—	—
—	—	—
—	—	—

COSEL

Model	LEA100F-15
Item	Ripple-Noise　リップルノイズ
Object	+15V6.7A

Temperature　25℃
Testing Circuitry　Figure A

1. Graph



Ripple-Noise is shown as p-p in the figure below.
Note: Slanted line shows the range of the rated load current.

リップルノイズは、下図ｐ－ｐ値で示される。
(注)斜線は定格負荷電流範囲を示す。

T1: Due to AC Input Line
入力商用周期
T2: Due to Switching
ｽｲｯﾁﾝｸﾞ周期



Fig. Complex Ripple Wave Form
図　リップル波形詳細図

2. Values

Load current [A]	Input Volt. 170 [V] Ripple-Noise [mV]	Input Volt. 264 [V] Ripple-Noise [mV]
0.0	20	20
1.0	45	45
2.0	50	50
3.0	50	50
4.0	55	55
5.0	60	60
6.7	70	70
7.4	70	70
—	—	—
—	—	—
—	—	—

COSEL

Model	LEA100F-15
Item	Overcurrent Protection 過電流保護
Object	+15V6.7A

Temperature 25℃
Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated load current.

(注)斜線は定格負荷電流範囲を示す。
10.5V以下は間欠状態。

2. Values

Output Voltage [V]	Input Volt. 170[V] Load Current [A]	Input Volt. 200[V] Load Current [A]	Input Volt. 264[V] Load Current [A]
15.00	8.88	8.87	8.87
14.25	8.87	8.86	8.86
13.50	8.84	8.82	8.80
12.00	8.73	8.71	8.71
10.50	8.88	8.89	8.89
—	—	—	—
—	—	—	—
—	—	—	—
—	—	—	—
—	—	—	—
—	—	—	—
—	—	—	—

COSEL

Model	LEA100F-15
Item	Overvoltage Protection 過電圧保護
Object	+15V6.7A

Testing Circuitry Figure A

1. Graph



Load 0%

Note: Slanted line shows the range of the rated ambient temperature.

(注)斜線は定格周囲温度範囲を示す。

2. Values

Ambient Temp. [℃]	Input Volt. 170[V]	Input Volt. 200[V]	Input Volt. 264[V]
	Operating Point [V]		
-20	18.3	18.3	18.3
-10	18.4	18.4	18.4
0	18.5	18.5	18.5
10	18.7	18.7	18.7
20	18.8	18.8	18.8
25	18.9	18.9	18.9
30	19.0	19.0	19.0
40	19.1	19.1	19.1
50	19.2	19.2	19.2
60	19.4	19.4	19.4
—	—	—	—

COSEL

Model	LEA100F-15
Item	Inrush Current　突入電流
Object	――――――――

Temperature　25℃
Testing Circuitry　Figure A



Input Voltage　200 V
Frequency　60 Hz
Load　100 %
Inrush Current
① 29.16 [A]
② 2.25 [A]



BC－3165

COSEL

Model	LEA100F-15		
Item	Dynamic Load Responce 動的負荷変動	Temperature Testing Circuitry	25℃ Figure A
Object	+15V6.7A		

Input Volt. 200 V

Cycle 1000 mS

Load Current

Min. Load ←→

Load 100 %



Min. Load ←→

Load 50 %



100 mV/div

10 ms/div

COSEL

Model	LEA100F-15		
Item	Rise and Fall Time 立上り、立下り時間	Temperature	25℃
		Testing Circuitry	Figure A
Object	+15V6.7A		

1. Graph

Input Volt. 170 V



2. Values

[mS]

Load \ Time	T d	T r	T s	T h	T f
50 %	315.5	9.5	325.0	88.8	49.8
100 %	315.5	9.5	325.0	43.5	27.3



BC−3165

COSEL

Model	LEA100F-15
Item	Ambient Temperature Drift 周囲温度変動
Object	+15V6.7A

Testing Circuitry Figure A

1. Graph



Load 100%

Note: Slanted line shows the range of the rated ambient temperature.

(注)斜線は定格周囲温度範囲を示す。

2. Values

Temperature [℃]	Input Volt. 170[V] Output Volt. [V]	Input Volt. 200[V] Output Volt. [V]	Input Volt. 264[V] Output Volt. [V]
-20	15.123	15.123	15.123
-10	15.125	15.125	15.125
0	15.126	15.126	15.126
10	15.126	15.126	15.126
20	15.126	15.126	15.126
25	15.127	15.127	15.127
30	15.129	15.129	15.129
40	15.125	15.125	15.125
50	15.121	15.121	15.121
60	15.114	15.114	15.114
—	—	—	—

BC-3165

COSEL

Model	LEA100F-15
Item	Minimum Input Voltage for Regulated Output Voltage 最低レギュレーション電圧
Object	+15V6.7A

Testing Circuitry Figure A

1. Graph



Note: Slanted line shows the range of the rated ambient temperature.

(注)斜線は定格周囲温度範囲を示す。

2. Values

Ambient Temp. [℃]	Load 50% Input Volt. [V]	Load 100% Input Volt. [V]
-20	72	73
-10	72	73
0	72	73
10	72	73
20	72	73
25	72	73
30	72	73
40	72	73
50	72	73
60	72	73
—	—	—

COSEL

Model	LEA100F-15
Item	Ripple Voltage (by Ambient Temp.) リップル電圧（周囲温度特性）
Object	+15V6.7A

Testing Circuitry Figure A

1. Graph



Input Volt. 200 V

Note: Slanted line shows the range of the rated ambient temperature.

(注)斜線は定格周囲温度範囲を示す。

2. Values

Ambient Temp. [℃]	Load 50% Ripple Output Volt. [mV]	Load 100% Ripple Output Volt. [mV]
-20	70	80
-10	55	65
0	45	55
10	45	50
20	40	45
25	35	40
30	30	35
40	25	30
50	25	30
60	25	30
—	—	—

COSEL

Model	LEA100F-15
Item	Time Lapse Drift 経時ドリフト
Object	+15V6.7A

Temperature 25 ℃
Testing Circuitry Figure A

1. Graph



Input Volt. 200V
Load 100%

2. Values

Time since start [H]	Output Voltage [V]
0.0	15.140
0.5	15.128
1.0	15.128
2.0	15.128
3.0	15.128
4.0	15.128
5.0	15.128
6.0	15.128
7.0	15.128
8.0	15.128

COSEL

Model	LEA100F-15	
Item	Output Voltage Accuracy 定電圧精度	Testing Circuitry Figure A
Object	+15V6.7A	

Output Voltage Accuracy

This is defined as the value of the output voltage, regulation load, ambient temperature and input voltage varied at random in the range as specified below.

Temperature : -10～50 ℃
Input Voltage : 170～264 V
Load Current : 0.00～6.70 A

* Output Voltage Accuracy = ±(Maximum of Output Voltage − Minimum of Output Voltage)／2

$$\text{* Output Voltage Accuracy (Ration)} = \frac{\text{Voltage Accuracy}}{\text{Rated Output Voltage}} \times 100$$

定電圧精度

周囲温度、入力電圧、負荷を下記仕様内で、任意に変動させたときの出力電圧の変動をいう。

周囲温度 -10～50 ℃
入力電圧 170～264 V
負荷電流 0.00～6.70 A

* 定電圧精度(変動値) ＝ ±(出力電圧の最高値－出力電圧の最低値)／2

$$\text{* 定電圧精度(変動率)} = \frac{\text{変動値}}{\text{定格出力電圧}} \times 100$$

Item	Temperature [℃]	Input Voltage [V]	Output Current [A]	Output Voltage [V]	Output Voltage Accuracy [mV]	Output Voltage Accuracy(Ration) [%]
Maximum Voltage	25	264	0.00	15.137	±9	±0.1
Minimum Voltage	50	264	6.70	15.121		

COSEL

Model	LEA100F-15
Item	Harmonic Current 高調波電流
Object	————

Temperature 25℃
Testing Circuitry Figure E

1. Input Current Waveform

——— Input Current

——— Envelope of the input current to classify equipment as Class D
ｸﾗｽDの機器を決定するための入力電流包絡線

1 A/div



2. Harmonic Current



——— Harmonic Current
高調波電流

——— Limits for Class A equipment
ｸﾗｽAの機器に対する限度値

Conditions	Values
Input Voltage [V]	230.6
Input Current [A]	0.584
Active Power [W]	124.4
Apparent Power[VA]	134.7
Frequency [Hz]	50
Power Factor	0.924
Output Power [W]	100.5

Harmonics order 高調波次数	Limits 限度値 [A]	Values 測定値 [A]
1	—	0.54880
2	—	0.00090
3	2.29402	0.19350
4	—	0.00010
5	1.13703	0.03430
6	—	0.00000
7	0.76800	0.01190
8	—	0.00000
9	0.39896	0.01860
10	—	0.00010
11	0.32914	0.00800
12	—	0.00030
13	0.20945	0.00420
14	—	0.00010
15	0.14961	0.00710
16	—	0.00000
17	0.13201	0.00360
18	—	0.00000
19	0.11811	0.00190
20	—	0.00000
21	0.10686	0.00350
22	—	0.00030
23	0.09757	0.00210
24	—	0.00010
25	0.08977	0.00170
26	—	0.00000
27	0.08312	0.00190
28	—	0.00000
29	0.07738	0.00310
30	—	0.00000
31	0.07239	0.00220
32	—	0.00010
33	0.06800	0.00140
34	—	0.00000
35	0.06412	0.00410
36	—	0.00000
37	0.06065	0.00060
38	—	0.00010
39	0.05754	0.00450
40	—	0.00010

COSEL

Model	LEA100F-15		
Item	Harmonic Current 高調波電流	Temperature Testing Circuitry	25℃ Figure E
Object	————		

1. Input Current Waveform

——— Input Current

——— Envelope of the input current to classify equipment as Class D
ｸﾗｽDの機器を決定するための入力電流包絡線



Conditions	Values
Input Voltage [V]	230.7
Input Current [A]	0.329
Active Power [W]	65.6
Apparent Power[VA]	76
Frequency [Hz]	50
Power Factor	0.863
Output Power [W]	50.25

2. Harmonic Current



——— Harmonic Current
高調波電流

——— Limits for Class A equipment
ｸﾗｽAの機器に対する限度値

Harmonics order 高調波次数	Limits 限度値 [A]	Values 測定値 [A]
1	—	0.29590
2	—	0.00090
3	2.29302	0.14080
4	—	0.00010
5	1.13654	0.00690
6	—	0.00000
7	0.76766	0.02400
8	—	0.00010
9	0.39879	0.00550
10	—	0.00030
11	0.32900	0.01020
12	—	0.00010
13	0.20936	0.00540
14	—	0.00010
15	0.14954	0.00480
16	—	0.00000
17	0.13195	0.00460
18	—	0.00030
19	0.11806	0.00230
20	—	0.00010
21	0.10682	0.00410
22	—	0.00010
23	0.09753	0.00150
24	—	0.00000
25	0.08973	0.00300
26	—	0.00030
27	0.08308	0.00230
28	—	0.00010
29	0.07735	0.00350
30	—	0.00000
31	0.07236	0.00180
32	—	0.00000
33	0.06797	0.00260
34	—	0.00010
35	0.06409	0.00230
36	—	0.00010
37	0.06063	0.00400
38	—	0.00010
39	0.05752	0.00300
40	—	0.00000

COSEL

Model	LEA100F-15	
Item	Condensation 結露特性	Testing Circuitry Figure A
Object	+15V6.7A	

1. Condensation test

Testing procedure is as follows.

① Keeping and cooling the unit in a tank at -10℃ for an hour with the input off.

② Taking it out of the tank and dewing itself in a room where the temperature is 25℃ and the humidity is 40%RH.

③ Testing electrical characteristics of the unit to confirm there be no fault.

1．結露特性試験

入力を切った状態で、恒温槽で－１０℃に冷却しておき、約１時間後に恒温槽から取り出し、室温２５℃、湿度４０%RHの状態におき結露させ、その電気的特性の測定を行い、異常のないことを確認する。

2．Values

Item	Data	Testing Conditions
Output Voltage [V]	15.132	Input Volt.: 200V, Load Current:6.7A
Line Regulation [mV]	1	Input Volt.: 170～264V, Load Current:6.7A
Load Regulation [mV]	8	Input Volt.: 200V, Load Current:0.0～6.7A

COSEL

Model	LEA100F-15
Item	Leakage Current 漏洩電流
Object	――――――――

Temperature 25℃
Testing Circuitry Figure B

1. Results

Standards	Leakage Current [mA]		
	Input Volt. 85 [V]	Input Volt. 100 [V]	Input Volt. 132 [V]
(A) DENTORI	—	—	—
(B) IEC60950	—	—	—

Standards	Leakage Current [mA]		
	Input Volt. 170 [V]	Input Volt. 230 [V]	Input Volt. 264 [V]
(B) IEC60950	0.31	0.43	0.49

2. Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.

交流入力の両相について測定し、その大きい方を漏洩電流測定値とする。

COSEL

Model	LEA100F-15	
Item	Line Noise Tolerance 入力雑音耐量	Temperature 25℃ Testing Circuitry Figure C
Object	+15V6.7A	

1. Results

Pulse Width [nS]	MODE	No protection failure should occur 保護回路の誤動作がない	DC-like Regulation of Output Voltage 出力電圧の直流的変動
50	COMMON	OK	no fluctuation
	NORMAL	OK	no fluctuation
1000	COMMON	OK	no fluctuation
	NORMAL	OK	no fluctuation

Conditions

Input Voltage :200 V
Pulse Voltage :2000 V
Pulse Cycle :10 mS
Pulse Input Duration:1 min. or more
Load :100 %

COSEL

Model	LEA100F-15		
Item	Conducted Emission 雑音端子電圧	Temperature Testing Circuitry	25℃ Figure D
Object	————————		

1. Graph

Remarks

Input Volt. 230V (CISPR Pub22 Class B)

Load 100 %

Limit1: [CISPR Pub22] Class B(QP)
Limit2: [CISPR Pub22] Class B(Ave.)



COSEL



Figure A



Figure B(DENTORI)



Figure B (IEC60950)



Figure C



Figure D



Figure E