

SNDHS250B series EMI/EMS Test resultApproved : Takahiro Yoneda
Takahiro YonedaPrepared : Tadashi Arai
Tadashi Arai

| No. | Test item | Conditions | Conditions of Acceptability | Result |
|-----|---|---|--|--------|
| 1 | Line conduction | (1) Rated input AC230V (2) Rated load (3) Ambient temp. 25±10°C (4) Testing circuitry Fig.1 | (1)Meets the undermentioned standard. FCC Part15 classA , VCCI classA CISPR22 classA , EN55022-A EN55011-A | OK |
| 2 | Radiated emission | (1) Rated input AC230V (2) Rated load (3) Ambient temp. 25±10°C (4) Testing circuitry Fig.1 | (1)Meets the undermentioned standard. FCC Part15 classA , VCCI classA CISPR22 classA , EN55022-A EN55011-A | OK |
| 3 | Static electricity immunity test (EN61000-4-2) | (1) Rated input DC280V (2) Rated load (3) Ambient temp. 25±10°C (4) Contact discharge voltage 8[kV] (EN61000-4-2 Level 4) | (1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure | OK |
| 4 | Radiated, radio-frequency, electromagnetic field immunity test (EN61000-4-3) | (1) Rated input DC280V (2) Rated load (3) Ambient temp. 25±10°C (4)Testing field strength (Level 3) ① 10[V/m] (80MHz to 1.0GHz) ② 3[V/m] (1.4GHz to 2.0GHz) ③ 1[V/m] (2.0GHz to 2.7GHz) | (1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure | OK |
| 5 | Electrical fast transient/ burst immunity test (EN61000-4-4) | (1) Rated input AC230V (2) Rated load (3) Ambient temp. 25±10°C (4) Test peak voltage 4[kV] (Level 4) (5) Testing circuitry Fig.2 | (1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure | OK |
| 6 | Surge immunity test (EN61000-4-5) | (1) Rated input AC230V (2) Rated load (3) Ambient temp. 25±10°C (4) Test voltage Line to line 2[kV] (Level 3) Line to earth 2[kV] (Level 3) (5) Testing circuitry Fig.1 | (1)The power supply is not stop. (2)Circuit does not malfunction. (3)No abnormality of the insulation destruction etc. (4)Parts are no damaged. | OK |
| 7 | Immunity to conducted disturbances, induced by radio-frequency fields (EN61000-4-6) | (1) Rated input DC280V (2) Rated load (3) Ambient temp. 25±10°C (4) Voltage level (e.m.f.) 10[V] (Level 3) | (1)No protection circuit failure. (2)No output voltage drop with control circuit failure. (3)No any other function failure | OK |

COSEL





Fig.1 Testing circuitry



SS1 : D10XB60 (SHINDENGEN)
 C1 : 100uF

Fig.2 Electrical fast transient/ burst immunity test Testing circuitry