

TEST DATA OF TAC-06-□ □ □

Noise Filter

Sep. 11, 2017

Approved by : Tadayuki Noda Tadayuki Noda Design Manager

Prepared by : Issei Okuno
Issei Okuno Design Engineer

COSEL CO.,LTD.





CONTENTS


1.Attenuation Characteristics	1
2.Leakage Current	3
3.Figure of Testing Circuitry	4

(Final Page 4)

COSEL

Model	TAC-06-□□□	Temperature Testing Circuitry Figure A
Item	Attenuation Characteristics	
Object	—	



COSEL



Model	TAC-06-□□□	Temperature	25°C
Item	Leakage Current	Testing Circuitry	Figure B
Object	_____		

1. Results

[mA]

Model	Standards	Input Volt.				Note
		200[V]	250[V]	400[V]	500[V]	
TAC-06-103	UL1283	0.23	0.28	0.45	0.57	
TAC-06-223	UL1283	0.52	0.65	1.0	1.3	
TAC-06-683	UL1283	1.4	1.8	2.8	3.6	

2. Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.

COSEL




Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement




Figure B Leakage current measurement (UL1283)