

TEST DATA OF TAC-100-□□□

Noise Filter

June. 20. 2008

Approved by : Toshio Watanabe
Toshio Watanabe Design Manager

Prepared by : Tadayuki Noda
Tadayuki Noda Design Engineer



COSEL CO.,LTD.

CONTENTS

| | |
|---|---|
| 1.Attenuation Characteristics | 1 |
| 2.Leakage Current | 3 |
| 3.Figure of Testing Circuitry | 4 |
| (Final Page 4) | |


COSEL

| | | | |
|--------|-----------------------------|-------------------|----------|
| Model | TAC-100-□□□ | Temperature | 25°C |
| Item | Attenuation Characteristics | Testing Circuitry | Figure A |
| Object | _____ | | |



COSEL

| | | |
|--------|-----------------------------|--|
| Model | TAC-100-□□□ | Temperature 25°C Testing Circuitry Figure A |
| Item | Attenuation Characteristics | |
| Object | _____ | |





| | | |
|--------|-----------------|--|
| | | Temperature 25°C Testing Circuitry Figure B |
| Model | TAC-100-□□□ | |
| Item | Leakage Current | |
| Object | _____ | |

1.Results

[mA]

| Model | Standards | Input Volt. | | | | | Note |
|-------------|-----------|-------------|---------|---------|---------|---------|------|
| | | 200 [V] | 250 [V] | 400 [V] | 480 [V] | 500 [V] | |
| TAC-100-103 | UL1283 | 0.62 | 0.78 | 1.3 | 1.5 | 1.6 | |
| TAC-100-223 | UL1283 | 1.4 | 1.8 | 2.8 | 3.3 | 3.5 | |
| TAC-100-333 | UL1283 | 2.1 | 2.7 | 4.2 | 5.1 | 5.3 | |

2.Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.




Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement




Figure B Leakage current measurement (UL1283)