

# TEST DATA OF TAC-20-□□□

## Noise Filter

Sep. 11 , 2017

Approved by :

Tadayuki Noda

Tadayuki Noda

Design Manager

Prepared by :

Issei Okuno

Issei Okuno

Design Engineer

**COSEL CO.,LTD.**






## CONTENTS

1.Attenuation Characteristics .....	1
2.Leakage Current .....	3
3.Figure of Testing Circuitry .....	4
(Final Page 4)	

**COSEL**

Model	TAC-20-□□□	Temperature Testing Circuitry Figure A
Item	Attenuation Characteristics	
Object	—	



**COSEL**



Model	TAC-20-□□□	Temperature	25°C
Item	Leakage Current	Testing Circuitry	Figure B
Object	_____		

## 1. Results

[mA]

Model	Standards	Input Volt.				Note
		200[V]	250[V]	400[V]	500[V]	
TAC-20-103	UL1283	0.23	0.28	0.45	0.57	
TAC-20-223	UL1283	0.52	0.65	1.0	1.3	
TAC-20-683	UL1283	1.4	1.8	2.8	3.6	

## 2. Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.


**COSEL**


Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement




Figure B Leakage current measurement ( UL1283 )