

ABNORMAL TEST RESULT

OF MODEL TAC-50, 60, 80, 100, 150

1. Did Cheese Cloth or Paper Glow?

No.

2. Did Ground Fuse Open?

No.

3. Dielectric breakdown?

No.

4. Other Results?

See the following pages .

(FMEA : 2/ 3 ~ 3/ 3)

(Abnormal Test Result: -)

There was no emission of flame, molten metal, ignition of cheesecloth, dielectric breakdown, opening of the ground fuse, other indication of a shock or fire hazard.

F M E A

Component	Mode		Comment	Output Voltage (V)
C11	Open		Normal operation.	
	Short		Normal operation.	
C12	Open		Normal operation.	
	Short		Normal operation.	
C13	Open		Normal operation.	
	Short		Normal operation.	
C21	Open		Normal operation.	
	Short		Normal operation.	
C22	Open		Normal operation.	
	Short		Normal operation.	
C23	Open		Normal operation.	
	Short		Normal operation.	
L11	Open	1or4	No hazard.	OUTPUT1:0
		2or5	No hazard.	OUTPUT1:0
		3or6	No hazard.	OUTPUT1:0
	Short	1-2, 4-5	Circuit breaker operate. No hazard.	OUTPUT1:0
		2-3, 5-6	Circuit breaker operate. No hazard.	OUTPUT1:0
		1-3, 4-6	Circuit breaker operate. No hazard.	OUTPUT1:0
R11	Open		Normal operation.	
R12	Open		Normal operation.	
R13	Open		Normal operation.	
CN11	Open	Except -50, -60	Normal operation.	
CN12	Open	Except -50, -60	Normal operation.	
CN13	Open	Except -50, -60	Normal operation.	



F M E A

Component	Mode		Comment	Output Voltage (V)
CN21	Open	Except -50, -60	Normal operation.	
CN22	Open	Except -50, -60	Normal operation.	
CN23	Open	Except -50, -60	Normal operation.	
Harness11	Open	Except -50, -60	Normal operation.	
Harness12	Open	Except -50, -60	Normal operation.	
Harness13	Open	Except -50, -60	Normal operation.	
Harness21	Open	Except -50, -60	Normal operation.	
Harness22	Open	Except -50, -60	Normal operation.	
Harness23	Open	Except -50, -60	Normal operation.	