

TEST DATA OF TAH-150-□□□-U

Noise Filter

May. 20. 2016

Approved by : Tadayuki Noda
Tadayuki Noda Design Manager

Prepared by : Shiro Gotani
Shiro Gotani Design Engineer

COSEL CO.,LTD.



CONTENTS

1. Attenuation Characteristics	1
2. Leakage Current	3
3. Figure of Testing Circuitry	4

(Final Page 4)




Model	TAH-150-□□□-U		
Item	Attenuation Characteristics	Temperature	25°C
Object		Testing Circuitry	Figure A





Model	TAH-150-□□□-U	Temperature 25°C Testing Circuitry Figure A	
Item	Attenuation Characteristics		
Object	_____		





		Temperature 25°C Testing Circuitry Figure B
Model	TAH-150-□□□-U	
Item	Leakage Current	
Object	_____	

1.Results

[mA]

Model	Standards	Input Volt.					Note
		200 [V]	250 [V]	400 [V]	480 [V]	500 [V]	
TAH-150-103-U	UL1283	0.65	0.78				
TAH-150-223-U	UL1283	1.49	1.80				
TAH-150-333-U	UL1283	1.95	2.45				

2.Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.






Figure B Leakage current measurement (UL1283)