

# TEST DATA OF TAH-60-□□□

## Noise Filter

May. 20. 2016

Approved by :

Tadayuki Noda  
Tadayuki Noda

Design Manager

Prepared by :

Shiro Gotani  
Shiro Gotani

Design Engineer

**COSEL CO.,LTD.**





## CONTENTS


1.Attenuation Characteristics .....	1
2.Leakage Current .....	3
3.Figure of Testing Circuitry .....	4

(Final Page 4)

**COSEL**

Model	TAH-60-□□□	Temperature	25°C
Item	Attenuation Characteristics	Testing Circuitry	Figure A
Object	_____		



**COSEL**



Model	TAH-60-□□□	Temperature Testing Circuitry	25°C Figure B	
Item	Leakage Current			
Object	_____			

## 1. Results

[mA]

Model	Standards	Input Volt.					Note
		200 [V]	250 [V]	400 [V]	480 [V]	500 [V]	
TAH-60-103	UL1283	0.65	0.78	1.30	1.50	1.55	
TAH-60-223	UL1283	1.49	1.80	2.80	3.45	3.50	
TAH-60-333	UL1283	1.95	2.45	3.85	4.60	4.90	

## 2. Condition

Leakage current value is concluded after measuring both phases of AC input and by choosing the larger one.

COSEL




Figure A - 1 Differential mode attenuation measurement




Figure A - 2 Common mode attenuation measurement




Figure B Leakage current measurement ( UL1283 )